

2007HS2 Basecase changes

Added Benewah-Shawnee 230 KV line to complete West of Hatwai project

Increased Montana to NW transfers from 673 to 1143 MW, decreased Montana load by 450 MW to accommodate transfers.

Increased BC load by 700 MW to accommodate 1000 MW increase transfer from Alberta (to 700 MW into BC) and increased transfer to NW (up 300 MW to 2850 MW).

Increase Alberta generation by 1000 MW and transfers to BC to +700 MW.

Increase NW load by 300 MW to accommodate net of transfer changes from Montana and BC and to California (up 300 MW to 4500 MW).
Increased Hermiston gen by 50 MW.

Port Westward generation (400 MW) is already in basecase

Reduced Bay Area gen to accommodate COI change.

Final transfers for case:
COI at COB = 4500 MW
PDCI = 3100 MW
MT to NW = 1143 MW
Alb to BC = 700 MW
BC to NW = 2565 MW

California load will be increased by 1500 MW for option cases

Any new buses will be added using 80,000 to 89,999 numbers

Updated 4-19-05